



LAKE JOHANNA FIRE DEPARTMENT

5545 LEXINGTON AVENUE NORTH • SHOREVIEW, MN 55126
OFFICE (651) 415-2100 • FAX (651) 486-8826

Food Truck Inspection Information Checklist

Must be completed prior to public occupancy

Vendor Name _____

Address _____

Vendor Representative _____ Phone _____

E-Mail _____

******The Fire Marshal and/or Fire Department representative will be out to inspect the vehicles between 12:00 and 16:00 on the day of set up******

******No items can be sold prior to inspection******

General Information Checklist

- _____ Obtain license or permit from the local authorities.
- _____ Ensure that all electrical appliances, fixtures, equipment, and wiring complies with the Minnesota State Fire Code
- _____ Check that appliances using combustible media are protected by an approved fire extinguishing system.
 - a) If using grease/oil, you will need a **K Extinguisher (MINIMUM - 10 lbs.)**.
 - b) If using any other heating source powered by electricity from a fuel source or electrical outlet, propane, solid fuel, etc. you will need an **ABC Extinguisher (MINIMUM - 2A10BC)**.
- _____ Ensure proper method of shutting off fuel systems.
- _____ Ensure that there is no public seating within the food truck.
- _____ Check that there is a clearance of at least 10 ft. away from buildings, structures, vehicles, and any combustible materials.
- _____ Ensure clearance is provided for the Fire Department to access fire hydrants.

Local sources for fire extinguishers:

K and ABC

- Nardini – 651-483-6631
- Cintas Fire Protection – 763-252-0967
- Reliable Fire Protection - 612-520-9243
- American Fire Protection – 952-641-7650
- Viking SupplyNet – 651-455-0325
- Summit Companies – 651-251-1880

Some Local Hardware stores will carry the 2A10BC and above. You need to verify that you have the appropriate size extinguishers for what cooking medium you have on your trailer/truck.

*****REMEMBER*** IF YOU DON'T HAVE THE APPROPRIATE EXTINGUISHING DEVICES, YOU WILL NOT BE ALLOWED TO SELL ITEMS. ***REMEMBER*****

Contact with any questions:

Lake Johanna Fire Department

Kris Rewald, Fire Marshal

krewald@lafd.org

651-415-2104